

Certificate

to Licence for ENEC Mark of Conformity

Agreement on the use of a commonly agreed Mark of Conformity for certain electrical equipment complying with European Standards

System No. 5, type testing with assurance of conformity by production and market surveillance

Ref. No. 21 ENEC 00278.02

Licensee Sedlbauer AG
W.-Sedlbauer-Str. 2, 94481 Grafenau
Germany

Factory Sedlbauer s.r.o.
Cicenice 111, 38771 Cicenice
Czechia

Certification Mark



Product Safety isolating transformer

Trade mark Polytronik

Models Series RSO 8.....
Series RSV 8.....

Parameters

Ratings	See page 2
Degree of protection	IP00
Protection class	Class II

Tested according to EN 61558-1:2005+A1:2009
EN 61558-2-6:2009

Remarks ---

This document is valid until **2024-03-09**.

This licence has been issued under the presumption and conditional on the fact that the licensee holds all necessary legal rights with regard to the product presented for testing and certification.

Test report no. 11-IK-0073.S06

Eurofins Electric & Electronic Product Testing AG
Swiss Certification Body

Patrick Gutensohn
Product Certification

Annex

ENEC Ref. No. 21 ENEC 00278.02

This Annex is an integral part of the ENEC Certificate and should only be read in conjunction with the Certificate.

Ratings:

Type:	Nominal data:	Protection class:	Degree of protection:
RSO 8XXXXX a) Without mounting accessories and unpotted b) Partially potted	PRI: up to 440 V SEC: up to 50 V f: 50/60 Hz Po: 10 VA up to 3000 VA *) Io: up to 50 A	II	IP00
RSV 8XXXXX Potted in resin	PRI: up to 440 V SEC: up to 50 V f: 50/60 Hz Po: 10 VA up to 500 VA *) Io: up to 20 A	II	IP00
	*) non-inherently short-circuit proof types up to 150 VA		